

पत्रांक - 1757 / जल परीक्षण / 33 दिनांक - 16-06-2026

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date: 16-06-2026

It is certified that an inspection team headed by Vivek Kumar,
(Name of Officer with designation) from Zab. Incharge PHED
inspected the Beena Public School, Aulhe Lathiyal Bazar
(Name & Address of the School) on 16-06-2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing No. C/VNS/JUNE26/0007, dated 05/06/2026,
of Regional Water Analysis Laboratory (PHED Lab), certified that the
Beena Public School (Name of school) has safe drinking
water facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/State/U.T. Govt.

This certificate is valid till One Year

Signature with Seal: [Signature]
Name : Prughan Kumar
Designation : Assistant Engineer
Name & Address of the Office / Department: P.N. (Gramin)

To

Beena Public School
Vasamasi

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.

Water Analysis Report



Regional Water Analysis Laboratory

Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005

Report No.: C/VNS/JUNE26/00001	Date: 05.06.2026	No. of Pages: 1
Customer Details		
Office Name and Address	Beena Public School, Audhe, Lathiya Crossing, NH-2, Varanasi-221011	
Ref. Letter No. & Date	NA	Date: 01.06.2026
Basic Details of Sample		
District	Varanasi	Block
Gram Panchayat	Audhe	Village
Habitation	NA	Location
Water Source	Submersible	Sample Code
Quantity of Sample	2000 mL (Normal)	Sampling date
Sample Received Date	01.06.2026	S. collected by
Sampling Method Used	NA	Sample Depositor
Analysis Start Date	02.06.2026	Analysis Completion date
Temperature-26.5°C, Humidity- 69%		

Test Result					
S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.61	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	0.64	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	301.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	18.02	250	1000	IS 3025 (Part 32): 2019 Argentometric method
5	Total Alkalinity, (as CaCO ₃) mg/l	230.00	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	196.00	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Calcium (as Ca), mg/l	32.08	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
8	Magnesium (as Mg), mg/l	27.84	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO ₄), mg/l	1.25	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
10	Nitrate (as NO ₃), mg/l	4.14	45	No relaxation	APHA 24rd Edition -4500- NO ₃ Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	0.35	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method) : 2023
12	Iron (as Fe), mg/l	BDL (<0.1)	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023

BDL-Below Detection Limit, NA- Not Analysed

- Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
5. Parameters above Permissible Limit are written in bold.
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.

ABHAY KUMAR PANDEY
(Report prepared by)

Laboratory Contact detail:

Email: aroupjn@gmail.com

Mobile No.:8400202287

*****END OF THE ANALYSIS REPORT*****

(Report Authorized & Reviewed by)

